



May 8, 2009

Laura S. Fisher, Chief  
UST Leak Prevention Unit  
State Water Resources Control Board  
1001 I Street, PO Box 2231  
Sacramento, CA 95812

## PetroTechnik

PetroTechnik Limited  
PetroTechnik House  
Olympus Close  
Whitehouse Industrial Estate,  
Ipswich, Suffolk IP1 5LN, UK

Tel: +44 (0)1473 243300  
Fax: +44 (0)1473 243301

e-mail: [info@upp.co.uk](mailto:info@upp.co.uk)

### RE: UPP compatibility with Biodiesel

Dear Ms. Fisher,

With regard to "Section 2631.2 – Biodiesel Blends – Variance from material compatibility certification requirements", I have attached third party test results confirming the compatibility of the UPP system with biodiesel fuel. Biodiesel blends are defined in Section 2631.2 (c) as a fuel that contains one percent to 99.99 percent biodiesel blended with diesel fuel.

The third party testing was conducted with 100% biodiesel on UPP lined primary pipe and on unlined secondary pipe manufactured to UL-971 (1995). The primary pipe was not changed for UL- 971(2005) and the secondary pipe is now constructed in the same manner as the primary pipe.

Based on these test results, PetroTechnik confirms that both the UL-971 (1995) and UL- 971 (2005) pipe are fully compatible with all percentages of biodiesel.

Should you have any questions concerning this matter, please contact me.

Sincerely,

David Lyzinski  
Vice President Engineering USA  
Phone: 856-273-9700  
Cell: 630-209-0166  
Email: [dlyzinski@upp-usa.com](mailto:dlyzinski@upp-usa.com)

Company registration No. 2631843. England

