



Wayne

Scott Negley

Director, Alternative Energy Products

July 14, 2010

To whom it may concern;

This letter is in response to your recent inquiries about compatibility of equipment with various fuels. Standard Dresser Wayne dispensers are manufactured for compatibility with the following formulations,

- Ethanol blends to 15% by volume. Note that some fuel filters are only compatible to E10 and may need to be upgraded for service with higher blends. Standard dispensers are UL-listed up to E10 only.
- MTBE blends to 15% by volume
- Bio-diesel to 20% by volume (B20) which complies with the ASTM D 6751 fuel standard. Given the nature of the fuel being composed of vegetable and other oils the potential exists for microbe growth and care should be taken in the selection and maintenance of fuel filters accordingly. This is also relevant given the nature of bio-diesel to act as a 'scrubbing' agent in the tank previously used for other fuels. Note that standard dispensers are UL-listed to B5 only.
- Kerosene
- AvGas and jet fuel provided any fuel path metal restrictions are addressed with fuel supplier
- Wayne dispensers are not compatible with any blend of methanol as even small percentage blends can cause problems with seals and other components.

Note that fuel must meet applicable ASTM standard.

Dresser Wayne Ovation and Reliance dispenser models are available from the factory listed for use with E85 provided the equipment is installed with approved hanging hardware. Vista models are available for use with E-85 contingent upon retailer acceptance of conditions of sale.

Regards,

Scott Negley

Dresser Wayne, Dresser Inc.

3814 Jarrett Way • Austin, TX 78728 • Phone: (512) 388-8460 • Fax: (512) 238-3930 • scott.negley@dresser.com • www.wayne.com