



February 15, 2011

Laura S. Fisher, Chief
Underground Storage Tank Technical Unit
State Water Resources Control Board
1001 I Street, PO Box 2231
Sacramento, CA 95812

2541 State St., Suite 205
Carlsbad, CA. 92008, USA
Telephone: 1-760-729-1093
Facsimile 1-760-729-1096
<http://www.plasteel.com>
E-Mail: tanktech@plasteel.com

Subject: Biodiesel UST Compatibility

Reference: UL Listed Plasteel® Elutron® Jacketed Underground Tanks
UL Listed Plasteel® Composite® Underground Tanks

Dear Ms. Fisher,

The referenced tanks are compatible for the storage of Biodiesel or Biodiesel blends.

Plasteel International Inc. is the Plasteel® Underground Tank Technology owner and licensor. Plasteel International Inc. does not manufacture or sell Plasteel® Underground Tanks.

Plasteel International Inc. licenses individual Plasteel® Tank Manufacturers worldwide to manufacture and sell UL Listed Underground Plasteel® Tanks.

The compatibility statement above is based on the fact that Biodiesel or Biodiesel blends are a flammable or combustible liquid depending on the flash point per N.F.P.A. 30, the Flammable and Combustible Liquids Code.

The referenced tanks are manufactured per Underwriters Laboratories Inc. (UL) Standard 58, Steel Underground Tanks for Flammable and Combustible Liquids in compliance with the California UST Regulations, Article 3, Section 2631. UL is an independent, third party, testing organization in compliance with Section 2631.

UL Standard 58 states in the Scope paragraph: **“These requirements cover horizontal atmospheric-type steel tanks for the storage underground of flammable and combustible liquids.”**

The referenced tanks are therefore considered to be compatible for the storage of Biodiesel or Biodiesel blends.

Sincerely,

Rick Sharpe
Vice President