



May 12, 2009

Laura S. Fisher, Chief
UST Leak Prevention Unit
State Water Resources Control Board
1001 I Street, PO Box 2231
Sacramento, CA 95812

Subject: iota® ELD compatibility with Bio Diesel Blends

Dear Ms. Fisher:

The purpose of this letter is to address concerns regarding potential product compatibility and/or performance issues associated with the iota® Enhanced Leak Detection (ELD) method when applied to systems storing various blends of bio diesel.

The iota® ELD test method is used to meet the Post Installation ELD requirements. Systems are tested upon installation, prior to receiving fuel or are completely emptied of fuel prior to testing. As a result there is no fuel in the system during testing and no interface with the fuel and the iota test equipment. Therefore, there we are confident that the performance and compatibility of the iota® ELD method will be unaffected when testing systems which are intended for storing bio diesel.

If you have any questions or concerns regarding any aspect of this letter or the iota® test method, please don't hesitate to call me directly at 970-420-6824.

Sincerely,
CGRS, Inc.

Eric L. Hick
President